

# VLMT.EX2534 - Special System Water Control Valves, Pressure-reducing and Pressure-control Type

## Special System Water Control Valves, Pressure-reducing and Pressure-control Type

See General Information for Special System Water Control Valves, Pressure-reducing and Pressure-control Type

### GRISWOLD INDUSTRIES, DBA CLA-VAL CO

EX2534

1701 PLACENTIA AVE

COSTA MESA, CA 92627-4416 USA

**Pilot-operated pressure-control valve**, consisting of the following models, types, sizes and pressures:

Model	Body Type	Nominal Pipe Size, NPS	End Configuration*	Max Rated Pressure (psig)	Outlet Pressure-setting Range (psig)
90G-21	Globe	1-1/2	Class 150 - F by F	250	50 - 175
90G-21	Globe	2, 2-1/2, 3, 4, 6, 8	Class 150 - F by F	250	30 - 165
90G-21	Globe	10,12	Class 150 - F by F	250	30 - 175
90G-21	Globe	1-1/2	Class 300 - F by F, G by G	300	50 - 175
90G-21	Globe	2, 2-1/2, 3, 4, 6, 8	Class 300 - F by F, G by G	300	30 - 165
90G-21	Globe	10,12	Class 300 - F by F	300	30 - 175
90G-21	Globe	1-1/2	T by T	300	50 - 175
90G-21	Globe	2, 2-1/2, 3	T by T	300	30 - 165
90A-21	Angle	2, 2-1/2, 3, 4, 6	Class 150 - F by F	250	30 - 165
90A-21	Angle	10,12	Class 150 - F by F	250	30 - 175
90A-21	Angle	2, 3	T by T	300	30 - 165
90A-21	Angle	1-1/2	Class 300 - F by F	300	50 - 175
90A-21	Angle	2, 2-1/2, 3, 4, 6, 8	Class 300 - F by F	300	30 - 165
90A-21	Angle	10,12	Class 300 - F by F	300	30 - 175
90A-21	Angle	1-1/2	G by G	300	50 - 175
90A-21	Angle	1-1/2, 2, 3, 4, 6, 8	G by G	300	30 - 165
90A-21	Angle	1-1/2	T by T	300	50 - 175
90A-21	Angle	2, 2-1/2, 3	T by T	300	30 - 165

F - Flanged

G - Grooved

T - Threaded

\* End configurations are intended to be installed on systems not exceeding end configurations' working capabilities.

The manufacturer's design and installation instructions include a description of the performance characteristics for both flowing and static conditions.

Pressure ratings of components installed downstream shall not be exceeded.

Last Updated on 2020-11-05

---

The appearance of a company's name or product in this database does not in itself assure that products so identified have been manufactured under UL's Follow-Up Service. Only those products bearing the UL Mark should be considered to be Certified and covered under UL's Follow-Up Service. Always look for the Mark on the product.

UL permits the reproduction of the material contained in the Online Certification Directory subject to the following conditions: 1. The Guide Information, Assemblies, Constructions, Designs, Systems, and/or Certifications (files) must be presented in their entirety and in a non-misleading manner, without any manipulation of the data (or drawings). 2. The statement "Reprinted from the Online Certifications Directory with permission from UL" must appear adjacent to the extracted material. In addition, the reprinted material must include a copyright notice in the following format: "© 2022 UL LLC"