



VPLX.EX5118 - Valves, Alarm

Valves, Alarm

[See General Information for Valves, Alarm](#)

HD FIRE PROTECT PVT LTD

EX5118

K-98, MIDC

AJANTA RD

JALGAON, 425003 INDIA

Alarm valve, Model A, 3, 4, 6 and 8 in. for rated pressure not exceeding 175 PSI for vertical installation only may be provided with constant pressure trim or variable pressure trim for use with Model RA retard chamber and Model GA water motor and gong.

Alarm valve, Model H, 3, 4, 6 and 8 in. size for rated pressure no exceeding 250PSI for vertical installation only may be provided with constant pressure trim or variable pressure trim for use with Model RC9 retard chamber and Model GA water motor and gong, with the end connections: flanged-flanged, flanged-grooved and grooved-grooved.

[Last Updated](#) on 2013-12-05

The appearance of a company's name or product in this database does not in itself assure that products so identified have been manufactured under UL's Follow-Up Service. Only those products bearing the UL Mark should be considered to be Certified and covered under UL's Follow-Up Service. Always look for the Mark on the product.

UL permits the reproduction of the material contained in the Online Certification Directory subject to the following conditions: 1. The Guide Information, Assemblies, Constructions, Designs, Systems, and/or Certifications (files) must be presented in their entirety and in a non-misleading manner, without any manipulation of the data (or drawings). 2. The statement "Reprinted from the Online Certifications Directory with permission from UL" must appear adjacent to the extracted material. In addition, the reprinted material must include a copyright notice in the following format: "© 2022 UL LLC"